

# Remote IO Module / Modbus transmitter UIO-8DI



### **Features**

- 8 PNP Digital Inputs
- Modbus RS-485 Protocol Interface.
- Convenient address selection rotatory switch from 1 99 Address
- Complete range of baud rate settings supported
- Suitable for both Din Rail and Wall Mountable
- Product Dimensions 110mm x 50mm x 55mm (L x W x H)

## Supported Modbus Function Codes

- 01 Read Coil Outputs
- 02 Read Discrete Inputs
- 03 Read Holding Registers
- 04 Read Input Registers
- 05 Write Single Coil
- 06 Write Single Register
- 15 Write Multiple Coils
- 16 Write Multiple Registers

# Discrete Inputs (Read Only)

(10001) to (10008)

- Input 1∼8 Status. 1 indicates Input is High and 0 indicates Low

## Coils (Read / Write)

(20009) to (20010)

Digital Input 1 ~ 2 Count Reset respectively
 Setting this bit to 1 will Reset the count value stored. This coil auto reset to 0 once the operation is complete

(20011) to (20012)

Digital Input 3 ~ 8 does not support counters

#### Input Registers (Read Only)

 $(30001) \sim (30002)$ 

Undefined

 $(30003) \sim (30004)$ 

- RPM value in 16bit signed for Digital Input 1 ~ 2 respectively

 $(30005) \sim (30006)$ 

- RPS value in 16bit signed for Digital Input 1 ~ 2 respectively

 $(30007) \sim (30008)$ 

Undefined

 $(30009) \sim (30012)$ 

- 32 bit unsigned Retentive memory Digital Input 1 & 2 Count values

 $(30013) \sim (30016)$ 

Digital Input 3 ~ 4 does not support counters

# Holding Registers (Read/Write)

 $(40001) \sim (40015)$ 

Undefined

 $(40016) \sim (40017)$ 

Digital Input 1 ~ 2 Mode Register respectively

- 0 − Digital Input 1~2 Discrete
- − 1 − Digital Input 1~2 RPM Measurement
- 2 − Digital Input 1~2 Production Counter

 $(40018) \sim (40019)$ 

PPR – Pulse per revolution for RPM  $1 \sim 2$ 

-  $1 \sim 2000$  – No.of pulses per revolution of the connected input

#### **Configuration Setting**

(40101)

Device Address as per the address switch – (Read Only)

(400102) (Reg. Value) -	Paud Pato	(40103) (Reg.Value) – Bits, Parity, Stop Bit
0 – 300	- Bauu Rale 8 <i>-</i> 14400	0 – 8 N 1
1 – 600	9 – 19200	1 – 8 E 1 2 – 8 O 1
2 – 1200	10 – 38400	3 – 8 N 2
3 – 1800 4 – 2400	11 – 57600 12 – 62500	4 – 8 E 2
5 – 4800	13 – 115200	5 – 8 O 2
6 - 7200		<b>Default. 0 – 8 N 1</b>
7 – 9600	<b>Default. 9 – 19200</b>	2010101101 0 011 2

#### Default Mode Switch

Default mode is handy when the serial communication setting are forgotten.

Setting the Address switch to 00 will put the device in default mode

Address Set to 00 - Default mode ON - Slave Address - 1, Baud 19200, 8N1 Address Set to non 00 - Default mode OFF

As per the saved configuration values.

Note:

No parameter selection is changed just by entering the default mode. All the parameters remains same including the communication settings unless changed by the master or if there is a corruption in data error indicated in normal mode the device will try to recover to Factory settings.

This mode can be used to read the present settings and/or change the settings

# Diagnostics

Tx LED
 Quick Blink Indicates Tx Data in Normal operation
 Quick Blink Indicates Rx Data in Normal operation
 Power LED
 Power Supply Status

#### **Electrical Details**

Power Supply: 12V to 24 V DC

Connector Type: 5.08mm Fixed Screw terminal block

#### **Top Connector**

#### RS485

A+	B-	E
1	2	3

#### **Bottom Connector**

P	U.	<b>\</b> \/	eı	r
1	v	vv	L.	L

TOWCI	
V+	V-
1	2


#### Sensor Connector

X1	X2	X3	X4	X5	X6	X7	X8
1	2	3	4	5	6	7	8

Connection Example

# Input Connection

# SW1 24V DC 10 02 Q1 Key-SW Example



# Output Connection

